

Kitemark™ Certificate

This is to certify that:

Sensor Tech Fire Fighting & Safety
Equipment Trading
Office No. 506
Al Qusais Industrial Area
P.O.Box: 231728
Dubai
United Arab Emirates

Holds Certificate Number:

KM 720321

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:



Chris Lewis - Certification Director, Product Certification

First Issued: 2020-01-23

Latest Issue: 2020-01-23

Effective Date: 2020-01-23

Expiry Date: 2023-01-22



003

Page: 1 of 3

...making excellence a habit.™

Kitemark™ Certificate

No. KM 720321

Model No	Description
WPP1	1 kg ABC powder (88% MAP), stored pressure. Fire rating 8A & 55B
WPP1N	1 kg ABC powder (23% MAP), stored pressure. Fire rating 8A & 34B
WPP2	2 kg ABC powder (42% MAP), stored pressure. Fire rating 13A & 89B
WPP2N	2 kg ABC powder (23% MAP), stored pressure. Fire rating 13A & 89B
WPP3	3 kg ABC powder (42% MAP), stored pressure. Fire rating 21A & 113B
WPP3N	3 kg ABC powder (23% MAP), stored pressure. Fire rating 13A & 113B
WPP4	4 kg ABC powder (42% MAP), stored pressure. Fire rating 27A & 144B
WPP4N	4 kg ABC powder (23% MAP), stored pressure. Fire rating 21A & 144B
WPP6	6 kg ABC powder (42% MAP), stored pressure. Fire rating 43A & 233B
WPP6N	6 kg ABC powder (23% MAP), stored pressure. Fire rating 27A & 183B
WPP6RS	6 kg ABC powder (90% MAP), stored pressure. Fire rating 55A & 233B
WPP9	9 kg ABC powder (42% MAP), stored pressure. Fire rating 55A & 233B
WPP9N	9 kg ABC powder (23% MAP), stored pressure. Fire rating 34A & 233B
WPP12	12 kg ABC powder (42% MAP), stored pressure. Fire rating 55A & 233B
WPP12N	12 kg ABC powder (23% MAP), stored pressure. Fire rating 43A & 233B
WPF2	2 litre foam (17% AFFF), stored pressure. Fire rating 8A & 55B
WPF2N	2 litre foam, stored pressure. Fire rating 5A & 55B
WPF3	3 litre foam (17% AFFF), stored pressure. Fire rating 13A & 89B
WPF6	6 litre foam (1.5% AFFF or premix), stored pressure. Fire rating 21A & 183B
WPF6RS	6 litre foam (16.7% AFFF), stored pressure. Fire rating 27A & 183B
WPF6N	6 litre foam, stored pressure. Fire rating 21A & 183B

First Issued: 2020-01-23

Latest Issue: 2020-01-23

Effective Date: 2020-01-23

Expiry Date: 2023-01-22

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 720321

Model No	Description
WPF9	9 litre foam powder (2% AFFF or premix), stored pressure. Fire rating 27A & 233B
WPF9N	9 litre foam, stored pressure. Fire rating 27A & 233B
WPWC2	2 litre wet chemical, stored pressure. Fire rating 8A, 34B & 25F
WPWC3	3 litre wet chemical, stored pressure. Fire rating 13A, 70B & 40F
WPWC6	6 litre wet chemical, stored pressure. Fire rating 21A, 113B & 75F
WPWA3	3 litre water + additive, stored pressure. Fire rating 13A
WPW6	6 litre water, stored pressure. Fire rating 13A
WPWA6	6 litre water + additive, stored pressure. Fire rating 27A
WPW9	9 litre water, stored pressure. Fire rating 21A
WPC2	2 kg carbon dioxide, steel cylinder. Fire rating 34B
WPC2A	2 kg carbon dioxide, aluminium cylinder. Fire rating 34B
WPC5	5 kg carbon dioxide, steel cylinder. Fire rating 70B
WPC5A	5 kg carbon dioxide, aluminium cylinder. Fire rating 70B
WPC5B	5 kg carbon dioxide, steel cylinder. Fire rating 89B

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2020-01-23

Latest Issue: 2020-01-23

Effective Date: 2020-01-23

Expiry Date: 2023-01-22

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.