



## HMRZ.EX27842 - GATE VALVES

## Gate Valves

See General Information for Gate Valves

**SENSOR TECH FIRE FIGHTING AND SAFETY EQUIPMENT TRADING**

EX27842

P.O. BOX 231728, OFFICE NO.506,AL SAOUD BUILDING,AL QUSAIS-4

DUBAI, UNITED ARAB EMIRATES

Resilient Seated Gate Valves.

Pattern	Model	Size, in.	End Configuration	Rated Pressure, psig
*NRS	ST1312-300 ST1313-300 ST1314-300	2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	300
OS&Y	ST0712-300 ST0714-300 ST0713-300	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F F by G G by G	300
*NRS	ST1312-250 ST1313-250 ST1314-250	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	250
OS&Y	ST0712-250 ST0714-250 ST0713-250	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F F by G G by G	250
*NRS	ST1312-200 ST1313-200 ST1314-200	2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	200
OS&Y	ST0712-200 ST0714-200 ST0713-200	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F F by G G by G	200
OS&Y	ST0712-250	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F	250
*NRS	ST1312-250	2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	250
OS&Y	ST0712-200	2, 2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	200
*NRS	ST1312-200	2.5, 3, 4, 5, 6, 8, 10, 12	F by F G by G F by G	200
OS&Y	ST0712	14, 16, 18	F by F	250
		20, 24	F by F	200

NRS	ST1312	14, 16, 18	F by F	250
		20, 24	F by F	200

\*NRS valve provided with a Post Indicator Flange.

Trademark and/or Tradename: **FWIC Valve**

Last Updated on 2018-08-03

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"