



# HLXS.EX27840 - BUTTERFLY VALVES

## Butterfly Valves

See General Information for Butterfly Valves

**SENSOR TECH FIRE FIGHTING AND SAFETY EQUIPMENT TRADING**  
 P.O. BOX 231728, OFFICE NO.506,AL SAOUD BUILDING,AL QUSAIS-4  
 DUBAI, UNITED ARAB EMIRATES

EX27840

| Model                  | Size, NPS  | Body Type | Pressure Rating, psig (Bar) | Indicator Post | Supervisory Switch* |
|------------------------|--|-----------|-----------------------------|----------------|---------------------|
| <b>Butterfly valve</b> |  |           |                             |                |                     |
| ST7011                 | 2.5,2.5(76.1mm)3,4,5(139.7mm),5,6(165.1mm),6,8,10,12 | Groove    | 300                         | —              | —                   |
|                        |  |           | 250                         |                |                     |
|                        |  |           | 200                         |                |                     |
| ST7022                 | 2.5,3,4,5,6,8,10,12                                  | Wafer     | 300                         | —              | —                   |
|                        |  |           | 250                         |                |                     |
|                        |  |           | 200                         |                |                     |

\* I = Indoor installation; O = Outdoor installation

Trademark and/or Tradename: **FWIC Valve**

Last Updated on 2018-08-03

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"